



Havant Borough Council
Civil Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/26/00070

Our ref
DSA000039187

Date
6th of February 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Variation of condition 2 of Planning Permission APP/24/00903 relating to minor changes to plans to be replaced by Drawing No. 24075-002C, A100 Rev A and A101 Rev A.

Site: 36 Summerhill Road, Waterloooville, PO8 8XE.

Thank you for your correspondence, please see our comments below regarding the above application.

Condition

Southern Water are unable to discharge condition 2 (Approved Plans) at this time due to the submitted documents not showing the required 3m easement between the existing sewer crossing the site and the proposed development.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development