



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17187-1		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	1
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

98.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17187-6		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	6
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

98.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17188-2		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	2
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17188-7		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	7
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17189-3		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	3
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17189-4		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	4
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17189-5		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	5
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17189-8		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	8
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17189-9		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	9
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Project Reference

Project Reference	EWC-6182	Author	Energy Team
Plot Reference	EWC-6182-17189-10		

To check verify this certificate visit <https://www.easywatercalc.co.uk/verification>

Company

Company Name	ATSPACE LTD	Company Address	Unit 3 & 4, Herts, SG8 8DL
--------------	-------------	-----------------	--------------------------------------

Site / Plot Information

Plot Name/Number	10
Plot Type	Former Links Childrens Centre
Site Address	Linnet Close, Waterloooville, Hampshire, PO8 9UY

Notice of Water Efficiency

Building Regulation Applies 36 (2) (a) applies. By following the Government's methodology for assessing water efficiency as set out in "Approved Document G 2015" the potential consumption of wholesome water per person per day

PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Summary of Calculations Per Type

Former Links Childrens Centre

Reference Number	EWC-6182-17187
Site Address	Linnet Close, Waterloooville , PO8 9UY
Prepared On	03-11-2025
Plot Numbers	1,6

By following the Government's national calculation methodology for assessing water efficiency in new dwellings this 1 bed dwelling, as built, achieves a water consumption of 98.3 litres per person per day.

TOILETS

Dual Flush Toilets

Type	Flow FULL	Flow PART
Dual Flush Toilet 1	4.00	2.60

WCs Litres/Person/Day : 13.53

BATHROOM

Bathroom Taps/Sinks

Type	Flow Rate
Wash Hand Basin 1	5.00

Bathroom Taps Litres/Person/Day : 9.48

Showers

Type	Flow Rate
Shower 1	8.00

Showers Litres/Person/Day : 44.80

Kitchen & Utility

Utility/Kitchen Sinks

Type	Flow Rate
Kitchen/Utility Sink 1	6.00



Kitchen & Utility Taps Litres/Person/Day : 13.00

Appliances

Washing Machines

Type	Litres Per Kilogram
Washing Machine 1	8.17

Washing Machines Litres/Person/Day : 17.16

Dishwashers

Type	Litres Per Place Setting
Dishwasher 1	1.25

Dishwashers Litres/Person/Day : 4.50

Final Calculations

Water Usage (Litres/Person)	102.47
Greywater/Rainwater Reused	0.00
Normalised Factor	0.91
Total Consumption	93.25
External Water Use Allowance	5.00
Total Consumption Part G	98.3
(Litres/Person/Day)	



PASS

98.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Former Links Childrens Centre

Reference Number	EWC-6182-17188
Site Address	Linnet Close, Waterloooville , PO8 9UY
Prepared On	03-11-2025
Plot Numbers	2,7

By following the Government's national calculation methodology for assessing water efficiency in new dwellings this 1 bed dwelling, as built, achieves a water consumption of 106.3 litres per person per day.

TOILETS

Dual Flush Toilets

Type	Flow FULL	Flow PART
Dual Flush Toilet 1	4.00	2.60

WCs Litres/Person/Day : 13.53

BATHROOM

Bathroom Taps/Sinks

Type	Flow Rate
Wash Hand Basin 1	5.00

Bathroom Taps Litres/Person/Day : 9.48

Baths

Type	Litres to Overflow
Bath 1	170.00

Baths Litres/Person/Day : 18.70

Showers

Type	Flow Rate
Shower 1	8.00

Showers Litres/Person/Day : 34.96



Kitchen & Utility

Utility/Kitchen Sinks

Type	Flow Rate
Kitchen/Utility Sink 1	6.00

Kitchen & Utility Taps Litres/Person/Day : 13.00

Appliances

Washing Machines

Type	Litres Per Kilogram
Washing Machine 1	8.17

Washing Machines Litres/Person/Day : 17.16

Dishwashers

Type	Litres Per Place Setting
Dishwasher 1	1.25

Dishwashers Litres/Person/Day : 4.50

Final Calculations

Water Usage (Litres/Person)	111.33
Greywater/Rainwater Reused	0.00
Normalised Factor	0.91
Total Consumption	101.31
External Water Use Allowance	5.00

**Total Consumption Part G
(Litres/Person/Day) 106.3**



PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day



Former Links Childrens Centre

Reference Number	EWC-6182-17189
Site Address	Linnet Close, Waterloooville , PO8 9UY
Prepared On	03-11-2025
Plot Numbers	3,4,5,8,9,10

By following the Government's national calculation methodology for assessing water efficiency in new dwellings this 2 bed dwelling, as built, achieves a water consumption of 106.3 litres per person per day.

TOILETS

Dual Flush Toilets

Type	Flow FULL	Flow PART
Dual Flush Toilet 1	4.00	2.60

WCs Litres/Person/Day : 13.53

BATHROOM

Bathroom Taps/Sinks

Type	Flow Rate
Wash Hand Basin 1	5.00

Bathroom Taps Litres/Person/Day : 9.48

Baths

Type	Litres to Overflow
Bath 1	170.00

Baths Litres/Person/Day : 18.70

Showers

Type	Flow Rate
Shower 1	8.00

Showers Litres/Person/Day : 34.96



Kitchen & Utility

Utility/Kitchen Sinks

Type	Flow Rate
Kitchen/Utility Sink 1	6.00

Kitchen & Utility Taps Litres/Person/Day : 13.00

Appliances

Washing Machines

Type	Litres Per Kilogram
Washing Machine 1	8.17

Washing Machines Litres/Person/Day : 17.16

Dishwashers

Type	Litres Per Place Setting
Dishwasher 1	1.25

Dishwashers Litres/Person/Day : 4.50

Final Calculations

Water Usage (Litres/Person)	111.33
Greywater/Rainwater Reused	0.00
Normalised Factor	0.91
Total Consumption	101.31
External Water Use Allowance	5.00

**Total Consumption Part G
(Litres/Person/Day) 106.3**



PASS

106.3 Litres Per Person Per Day

Target: 110 Litres Per Person Per Day