



Summary

Project Reference	EWC-6182	Author	Energy Team
Company Name	ATSPACE LTD	Site Address	Linnet Close, Waterlooville , PO8 9UY
Number of Types	3	Number of Plots	10

Type	Plot	Plot Ref	Target	Achieved	Result
Former Links Childrens Centre	1	EWC-6182-17187-1	110ltr	98.3ltr	PASS
Former Links Childrens Centre	6	EWC-6182-17187-6	110ltr	98.3ltr	PASS
Former Links Childrens Centre	2	EWC-6182-17188-2	110ltr	106.3ltr	PASS
Former Links Childrens Centre	7	EWC-6182-17188-7	110ltr	106.3ltr	PASS
Former Links Childrens Centre	3	EWC-6182-17189-3	110ltr	106.3ltr	PASS
Former Links Childrens Centre	4	EWC-6182-17189-4	110ltr	106.3ltr	PASS
Former Links Childrens Centre	5	EWC-6182-17189-5	110ltr	106.3ltr	PASS



Type	Plot	Plot Ref	Target	Achieved	Result
Former Links Childrens Centre	8	EWC-6182-17189-8	110ltr	106.3ltr	PASS
Former Links Childrens Centre	9	EWC-6182-17189-9	110ltr	106.3ltr	PASS
Former Links Childrens Centre	10	EWC-6182-17189-10	110ltr	106.3ltr	PASS



Summary of Calculations

Former Links Childrens Centre

Reference Number	EWC-6182-17187
Site Address	Linnet Close, Waterloooville , PO8 9UY
Prepared On	03-11-2025
Plot Numbers	1,6

By following the Government's national calculation methodology for assessing water efficiency in new dwellings this 1 bed dwelling, as built, achieves a water consumption of 98.3 litres per person per day.

TOILETS

Dual Flush Toilets

Type	Flow FULL	Flow PART
Dual Flush Toilet 1	4.00	2.60

WCs Litres/Person/Day : 13.53

BATHROOM

Bathroom Taps/Sinks

Type	Flow Rate
Wash Hand Basin 1	5.00

Bathroom Taps Litres/Person/Day : 9.48

Showers

Type	Flow Rate
Shower 1	8.00

Showers Litres/Person/Day : 44.80

Kitchen & Utility

Utility/Kitchen Sinks



Type	Flow Rate
Kitchen/Utility Sink 1	6.00

Kitchen & Utility Taps Litres/Person/Day : 13.00

Appliances

Washing Machines

Type	Litres Per Kilogram
Washing Machine 1	8.17

Washing Machines Litres/Person/Day : 17.16

Dishwashers

Type	Litres Per Place Setting
Dishwasher 1	1.25

Dishwashers Litres/Person/Day : 4.50

Final Calculations

Water Usage (Litres/Person)	102.47
Greywater/Rainwater Reused	0.00
Normalised Factor	0.91
Total Consumption	93.25
External Water Use Allowance	5.00
Total Consumption Part G	98.3
(Litres/Person/Day)	



Former Links Childrens Centre

Reference Number	EWC-6182-17188
Site Address	Linnet Close, Waterloooville , PO8 9UY
Prepared On	03-11-2025
Plot Numbers	2,7

By following the Government's national calculation methodology for assessing water efficiency in new dwellings this 1 bed dwelling, as built, achieves a water consumption of 106.3 litres per person per day.

TOILETS

Dual Flush Toilets

Type	Flow FULL	Flow PART
Dual Flush Toilet 1	4.00	2.60

WCs Litres/Person/Day : 13.53

BATHROOM

Bathroom Taps/Sinks

Type	Flow Rate
Wash Hand Basin 1	5.00

Bathroom Taps Litres/Person/Day : 9.48

Baths

Type	Litres to Overflow
Bath 1	170.00

Baths Litres/Person/Day : 18.70

Showers

Type	Flow Rate
Shower 1	8.00

Showers Litres/Person/Day : 34.96



Kitchen & Utility

Utility/Kitchen Sinks

Type	Flow Rate
Kitchen/Utility Sink 1	6.00

Kitchen & Utility Taps Litres/Person/Day : 13.00

Appliances

Washing Machines

Type	Litres Per Kilogram
Washing Machine 1	8.17

Washing Machines Litres/Person/Day : 17.16

Dishwashers

Type	Litres Per Place Setting
Dishwasher 1	1.25

Dishwashers Litres/Person/Day : 4.50

Final Calculations

Water Usage (Litres/Person)	111.33
Greywater/Rainwater Reused	0.00
Normalised Factor	0.91
Total Consumption	101.31
External Water Use Allowance	5.00
Total Consumption Part G	106.3
(Litres/Person/Day)	



Former Links Childrens Centre

Reference Number	EWC-6182-17189
Site Address	Linnet Close, Waterloooville , PO8 9UY
Prepared On	03-11-2025
Plot Numbers	3,4,5,8,9,10

By following the Government's national calculation methodology for assessing water efficiency in new dwellings this 2 bed dwelling, as built, achieves a water consumption of 106.3 litres per person per day.

TOILETS

Dual Flush Toilets

Type	Flow FULL	Flow PART
Dual Flush Toilet 1	4.00	2.60

WCs Litres/Person/Day : 13.53

BATHROOM

Bathroom Taps/Sinks

Type	Flow Rate
Wash Hand Basin 1	5.00

Bathroom Taps Litres/Person/Day : 9.48

Baths

Type	Litres to Overflow
Bath 1	170.00

Baths Litres/Person/Day : 18.70

Showers

Type	Flow Rate
Shower 1	8.00

Showers Litres/Person/Day : 34.96



Kitchen & Utility

Utility/Kitchen Sinks

Type	Flow Rate
Kitchen/Utility Sink 1	6.00

Kitchen & Utility Taps Litres/Person/Day : 13.00

Appliances

Washing Machines

Type	Litres Per Kilogram
Washing Machine 1	8.17

Washing Machines Litres/Person/Day : 17.16

Dishwashers

Type	Litres Per Place Setting
Dishwasher 1	1.25

Dishwashers Litres/Person/Day : 4.50

Final Calculations

Water Usage (Litres/Person)	111.33
Greywater/Rainwater Reused	0.00
Normalised Factor	0.91
Total Consumption	101.31
External Water Use Allowance	5.00
Total Consumption Part G	106.3
(Litres/Person/Day)	