
RE: PR202601-107615 (APP/26/00015) - Havant College, Barncroft Way, Havant, PO9 1QL

From [REDACTED]
Date Tue 03/02/2026 16:18
To Fox, Jennie <Jennie.Fox@havant.gov.uk>

Hi Jennie

Please accept this response as written confirmation we are happy to comply with the condition as specified below;

"It is therefore requested that 2.4m timber hoarding with minimum mass of 10kg/m2 with gaps and joints and edges sealed is installed around the compound area (material storage, loading and unloading, skips) to minimise noise from construction activities impacting residents."

Please let me know if you require anything further

Many thanks

Glyn

[REDACTED]

From: Fox, Jennie <Jennie.Fox@havant.gov.uk>
Sent: Friday, January 23, 2026 8:47 AM
To: [REDACTED]
Subject: Fw: PR202601-107615 (APP/26/00015) - Havant College, Barncroft Way, Havant, PO9 1QL

Good morning Mr Knaresborough,

Please the response below from our Environmental Health team. Would you be happy to either revise the documents or provide written confirmation that timber hoarding will be used as per their recommendation?

Kind regards,

Jennie Fox

Planning Officer | T: 07880 777478
Development Management
Planning Services
Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

Working pattern: Monday – Friday

Advance Notice of Leave: 19th February 2026 returning 25th February 2026

Certified Carbon Literate



In August 2025, the council moved to a new case management system, across Planning Development, Licensing and Environmental Health. This change involved moving 25 years' worth of data from multiple systems into one new system and learning how to use the new system.

Our officers have been working hard to continue working throughout the change, but there was a period of downtime, and we are still working through some of the backlog. As a result, our response times are longer than usual, and we apologise for any inconvenience this may cause.

Thank you for your understanding and patience.

Your privacy matters. Go to havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.

From: Milligan, Craig <Craig.Milligan@havant.gov.uk>

Sent: 23 January 2026 07:46

To: Fox, Jennie <Jennie.Fox@havant.gov.uk>; Havant Planning and Development Mailbox New <planning.developmentnew@havant.gov.uk>

Subject: PR202601-107615 (APP/26/00015) - Havant College, Barncroft Way, Havant, PO9 1QL

Dear Jennie,

Planning Application Reference: APP/26/00015

Description: Discharge of Conditions 7, 8 & 9 of Planning Application APP/25/00403

Location: Havant College, Barncroft Way, Havant, PO9 1QL

Thank you for consulting Environmental Health (pollution) regarding the above discharge of condition application. The C&G Construction Environmental Management Plan Revision 01 (dated January 2026) and appended Site Contractor and Material Storage Plan have been reviewed

Condition 7 & 8 - Contractor and Material Storage Plan & Construction Environmental Management Plan

The information provided is largely sufficient for the purposes of discharging Conditions 7 and 8. The documents outline the intended site setup, construction working hours, delivery routes, noise controls, dust mitigation, and waste management procedures, which are broadly in accordance with standard best practice.

The CEMP confirms the following relevant measures:

- Standard construction working hours (08:00–18:00 Mon–Fri; 08:00–13:00 Sat)
- Commitment to noise control measures under the *Control of Pollution Act 1974* and *Environmental Protection Act 1990* (e.g., turning off plant when not in use, fitting silencers, throttling back equipment)

- Dust suppression measures including dampening spoil heaps, sheeting of loads, and use of LEV where appropriate
- Waste segregation and prohibition of burning on site

However, there are concerns that the proposed security [Heras] fencing provides no acoustic mitigation for the storage compound, loading/unloading areas, and skip operations, despite the close proximity to neighbouring dwellings.

It is therefore requested that 2.4m timber hoarding with minimum mass of 10kg/m² with gaps and joints and edges sealed is installed around the compound area (material storage, loading and unloading, skips) to minimise noise from construction activities impacting residents.

Subject to the installation of suitable acoustic hoarding as outlined above, the submitted Construction Environmental Management Plan and Contractor/Storage Plan are considered acceptable.

The requested addition should be secured via an updated plan or written confirmation from the applicant prior to discharge of the conditions.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,

Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.

CAUTION: This email came from outside of the council - only open links and attachments that you're expecting.