

Planning Application Reference: APP/26/00141

Description: Discharge of condition 1 of Planning Permission APP/25/00359

Location: Trevanion, 1 Beach Road, Emsworth, PO10 7JS

Having reviewed the Sustainable Acoustics Technical Memorandum, I am satisfied that the document confirms the barrier exceeds 1.6 m in height and achieves a minimum surface mass of 14 kg/m². The calculations are reliable, and the noise rating level of the ASHP and condenser units is not expected to exceed 37 dB L_Ar,Tr at the nearest receptor.

I am satisfied that the submitted information is sufficient and recommend that the condition may be discharged.

Kind regards

Craig Milligan

Environmental Health Officer