

Havant Borough Council - Development  
Control  
By Email

Reference: PA-0000666/01  
Customer reference: APP/25/00796  
02 April 2026

Dear Narinder,

**Discharge of Conditions listed below re planning permission APP/24/00405:  
Condition No. 6 (Community Liaison Plan), Condition No. 26 (Framework  
Construction Traffic Management Plan), Condition No. 38 (Phasing Plan) Partial  
Discharge for the conditions below: Condition No. 20 (Pollution Management and  
Mitigation Plan) for Phases 2 and 3 of the development; Condition No. 25  
(Construction Traffic Management Plan (CTMP) for Phases 2 and 3 of the  
development; Condition No. 33 (Details of Works Area/Compounds) for Phases 2 and  
3 of the development.**

**Pipeline from proposed reservoir near Middle Park Way to Bedhampton Pumping  
Station, Meyrick Road, Havant**

Thank you for consulting the Environment Agency on the above discharge of conditions.

Of the conditions listed above, condition 20 is the only one that was requested by the Environment Agency and therefore the only one on which we will provide comment.

Condition 20

We have reviewed the submitted documents, in particular the Pollution Management and Mitigation Plan and confirm that we have no objection to the discharge of the condition 20.

We would however wish to highlight a point in relation to the Pollution Management and Mitigation Plan. We note that two products listed in the safety information, Adomast Adostrike and Adomast Adotard, are identified as containing kerosene, which is classified as a hazardous substance for groundwater. It was not clear whether these products are intended for use within the scheme, as we could not find them referred to elsewhere in the report.

The use of hazardous substances within a Source Protection Zone must be robustly controlled, with all appropriate safeguards in place. If there is an intention to use these products directly in the ground, this will need to be agreed with ourselves prior to their use.

If you have any questions regarding our response, please contact [laura.lax@environment-agency.gov.uk](mailto:laura.lax@environment-agency.gov.uk).

creating a better place  
for people and wildlife



Yours sincerely,

Laura Lax,

+442084745902

[laura.lax@environment-agency.gov.uk](mailto:laura.lax@environment-agency.gov.uk)

Romsey Depot, The Gables, Canal Walk, Romsey, Hampshire, SO51 7LP