

Planning Application Reference: APP/26/00170

Description: Display of 5No illuminated signs and 6No non-illuminated signs.

Location: 258 Havant Road, Hayling Island, PO11 0LP

Further to my previous comments, to overcome the objection from Environmental Health (pollution) the applicant must submit a lighting strategy to demonstrate that external lighting shall comply with criteria detailed in ILP GN01 'The reduction of obtrusive light', such that the sign luminance does not exceed 50cd/m2.

It is further recommended that light colour (CCT) does not exceed 3000k.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX