
Ref: PR202604-110092 (APP/26/00234) - The Ship Inn, Langstone Road, Havant, PO9 1RD

From Milligan, Craig <Craig.Milligan@havant.gov.uk>

Date Fri 24/04/2026 08:50

To Fox, Jennie <Jennie.Fox@havant.gov.uk>; Havant Planning and Development Mailbox New
<planning.developmentnew@havant.gov.uk>

Planning Application Reference: APP/26/00234

Description: Discharge of Condition 5 of APP/24/01000

Location: The Ship Inn, Langstone Road, Havant, PO9 1RD

Condition 5

The following documents have been reviewed:

- RBA Transformer noise review letter ref: 14322.LE01.0, dated 13th March 2026
- RBA report ref 14322.RP01.PNA.2, dated 9 September 2025
- Transformer Laboratory Noise Level Test Report, dated 05 March 2021

I am satisfied that the guaranteed sound power level of the confirmed plant is 1dB below the level assessed in the RBA report ref 14322.RP01.PNA.2, dated 9 September 2025. The RBA letter ref 14322.LE01.0 confirms that the built enclosure, orientation of plant and positioning of louvres are as assessed in report ref 14322.RP01.PNA.2.

I am therefore satisfied that the technical information provided demonstrates compliance with calculated noise levels in the assessment and that noise threshold criteria in the condition should be comfortably achieved.

The information is sufficient to discharge the condition.

Kind regards

Craig Milligan

Environmental Health Officer

Environmental Health, Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.