



DSA000052516 / APP/26/00174

From luke bottrill [REDACTED]**To** SouthernWaterPlanning@southernwater.co.uk <SouthernWaterPlanning@southernwater.co.uk>

2 attachments (8 MB)

Consultee response - Southern Water.pdf; IMG_8777.jpeg;

Hello,

I am writing in reply to your letter dated 27th March 2026.

I have spoken with Havant Borough Council, our architect and builder about the matter. Our builder came and took measurements and indicated that the closest footing to the sewer network is more than 4 meters, not within the 3m area of concern highlighted within the letter.

We have lifted the existing manhole cover (photo attached) which the extension would join into and it is over 800mm deep, the builder was more than satisfied that there is sufficient drop from the extension as well. They have confirmed that there would be no unacceptable impact on the sewer network.

Please advise what, if anything you require in addition to this resolve this concern.

Many thanks,

Luke Bottrill, 98 Roundway
[REDACTED]