Planning Application Reference: APP/26/00285

Description: Installation of new HVAC to Unit 8A with the incorporation of 3 No. stacked external condensing units located on the rear wall of the building.

Location: Unit 8, Wellington Retail Park, 2 Hambledon Road, Waterlooville, PO7 7FG

Thank you for consulting Environmental Health (pollution) regarding the above proposal.

No concerns of adverse noise impacts to residents given the quoted sound power levels of plant detailed in the drawing entitled 'Proposed Rear Elevation & Plan | Sheet Number: 89937-U-1110 Rev 1.0' (dated 22.04.2026). An online mapping review indicates that the nearest residential dwelling is approximately 170m east of the development and that other commercial units provide significant screening.

No objection to the proposals.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,

Civic Centre Road, Havant, PO9 2AX