
Ref: PR202605-110702 (APP/26/00289) - Waterloo Park, Elettra Avenue, Waterlooville

From Milligan, Craig <Craig.Milligan@havant.gov.uk>

Date Tue 16/06/2026 18:21

To Fox, Jennie <Jennie.Fox@havant.gov.uk>; Havant Planning and Development Mailbox New
<planning.developmentnew@havant.gov.uk>

Planning Application Reference: APP/26/00289

Description: Discharge of Conditions 8 & 14 of Planning application APP/21/00399.

Location: Waterloo Park, Elettra Avenue, Waterlooville

Condition 14

The Biddle document entitled 'HR3500 HEAT RECOVERY UNIT INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS | Ref:0108480-1-3 UK' has been reviewed.

Environmental Health (pollution) is satisfied that there is low risk of the proposed plant resulting in adverse noise impacts to residents given the plant sound power level provided by the manufacturer, screening provided by other buildings and the separation distance to the nearest dwelling.

With regards to noise considerations, I am satisfied the submitted information is sufficient to discharge the condition provided the submitted details comprise all extraction equipment to be installed relevant to Unit A, and that the equipment is retained and maintained in accordance with the manufacturer's instructions.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health, Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.