from Southern Water

Your ref
APP/26/00174

Our ref
DSA000052516

Date
10th July 2026

Contact
Tel 0330 303 0119

Havant Borough Council
Civil Centre Road
Havant
Hampshire
PO9 2AX

Dear Sir/Madam,

Details: Single storey front extension.
Site: 98 Roundway, Waterlooville, PO7 7QB.

Thank you for your correspondence. Please see our comments below regarding the above planning consultation application.

Development Site is not within Southern Water's Water Supply Area

The development site is not located within Southern Water's statutory area for water supply services. Please contact Portsmouth Water, who are the relevant statutory undertaker.

We had previously indicated a build over application was required for this application, but following further discussions this is no longer necessary, and Southern Water has no objections to this proposal.

Please note, surface water should not be disposed of into a public foul sewer and must comply with the Hierarchy of H3 of the Building Regulations. For more details, refer to the Drainage and Waste Disposal: Approved Document H on the GOV.UK website.

Any new connections to the public sewerage system will require a New Sewer Connection application (also known as a Section 106) to be submitted and approved by Southern Water.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670