

Certificate



Premier Tech Water and Environment Ltd.

2 Whitehouse Way, South West Industrial Estate, SR8 2RA, Peterlee, County Durham, UK

EN 12566-3, Annex A, B and C

Small wastewater treatment systems for up to 50 PT

Small wastewater treatment system "Rewatec Solido Smart"

One-chamber SBR system in one PE tank

Test report PIA2015-239B22.e

Evaluation of the nominal sequences of the 38-week

Nominal organic daily load	0.30 kg BOB ₅ /d		
Nominal hydraulic daily load	0.90 m ³ /d		
Material	Polyethylene		
Watertightness	pass		
Structural behaviour (pit test)	pass (also wet		
Durability	pass		
Treatment efficiency	Efficiency	Effluent	
	COD	95.1 %	39 mg/l
	BOD ₅	98.5 %	5 mg/l
	NH ₄ -N*	98.0 %	0.7 mg/l
	N _{tot}	83.1 %	10 mg/l
	P _{tot}	68.5 %	2.3 mg/l
	SS	97.1 %	13 mg/l

Evaluation of the complete 38-week testing

Electrical consumption 0.81 kWh/d

**determined for temperatures $\geq 12^{\circ}$ C in the bioreactor*

Tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH

(PIA GmbH)

Hergenrather Weg 30

52074 Aachen, Germany

This document replaces neither the declaration of performance nor the CE marking.



Notified Body
No.: 1739



Deutsche
Akkreditierungsstelle
D-PL-17712-01-00

PIA - Sustainable Certification



geprüft - tested - testé

M. Wermter/ D.Schmitz

November 2021