



Havant Borough Council  
Civil Centre Road  
Havant  
Hampshire  
PO9 2AX

**Your ref**  
APP/26/00486

**Our ref**  
DSA000021659

**Date**  
23<sup>rd</sup> of July 2026

**Contact**  
Tel 0330 303 0119

Dear Sir/Madam,

**Proposal:** Side and rear extensions, alterations to fenestration, new materials to exterior and alterations and extensions to the roof including the extension of the dormers. Amendments to APP/23/00181.

**Site:** 8 Queens Road, Waterloooville, PO7 7SB.

Thank you for your correspondence, please see our comments below regarding the above application.

#### **Development Site is not within Southern Water's Supply Area**

The development site is not located within Southern Water's statutory area for water supply services. Please contact Portsmouth Water who are the relevant statutory undertaker.

#### **Tree Planting**

We have restrictions on the proposed tree planting adjacent to Southern Water sewers, rising mains or water mains. Reference should be made to Southern Water's publication "A Guide to Tree Planting near water Mains and Sewers" ([https://www.southernwater.co.uk/media/pddob0vn/ds-tree-planting-guide-1\\_nwm.pdf](https://www.southernwater.co.uk/media/pddob0vn/ds-tree-planting-guide-1_nwm.pdf)) and the Sewerage Sector Guidance (<https://www.water.org.uk/sewerage-sector-guidance-approved-documents/>) with regards to any landscaping proposals and our restrictions and maintenance of tree planting adjacent to sewers, rising mains and water mains.

**Condition:** In order to protect public apparatus, Southern Water requests that if consent is granted, the following pre commencement condition is attached to the planning permission; The developer must advise the local authority (in consultation with Southern Water) of the landscaping proposals in proximity of public apparatus in order to protect it in accordance with Southern Water's guidance, prior to the commencement of the development.

### **Rear / side extension build-over/close-to a sewer**

It appears that the developer is intending to build-over/close-to a public foul sewer which is crossing the site. Building over a “public sewer” is not normally permitted by Southern Water. An investigation of the sewer is required to confirm its size and depth, ascertain its condition, number of properties served and potential means of access before any decision can be made as to whether it would be acceptable for Southern Water to allow building-over/close-to the sewer. The length of sewer to be built over under the terms of Part H of the Building Regulations dictates that the matter is determined by the sewerage undertaker, which in this case is Southern Water. The conditions and application associated with the build-over/close-to a public sewer are available at Southern Water's Get Connected service: <https://developerservices.southernwater.co.uk>

**Condition:** In order to protect drainage apparatus, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; prior to the commencement of development, the developer must advise the local authority, in consultation with Southern Water, of measures which will be undertaken to protect the public sewers.

*It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.*

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: [southernwater.co.uk](https://southernwater.co.uk) or by email at: [SouthernWaterPlanning@southernwater.co.uk](mailto:SouthernWaterPlanning@southernwater.co.uk)

Yours faithfully,

Future Growth Planning Team  
[southernwater.co.uk/developing-building/planning-your-development](https://southernwater.co.uk/developing-building/planning-your-development)