

From: [Milligan, Craig](#)
Sent: 25 August 2026 21:35
To: [Sheath, Denise](#); [Havant Planning and Development Mailbox New](#)
Subject: Ref: PR202608-113624 (APP/26/00188) - 32,
New Lane , Havant, PO9 2NG

Planning Application Reference: APP/26/00188

Description: Site alterations comprising the installation of plant and associated works to facilitate Electric Vehicle charging infrastructure

Location: 32, New Lane , Havant, PO9 2NG

Having reviewed the amended SMR Architects drawing entitled 'PROPOSED SUBSTATION DETAILS | Ref: 8085 - SMR - 15 - ZZ - DR - A - 2004 - S4 -P2' (dated 03.08.2026), it is noted that a generator access point is notated on the specification diagram however no supporting information relating to generator provision has been submitted with the application.

As such, further information is required regarding the intended use of the generator cable access point shown on the drawing.

Should the use of any generators be proposed, details of the frequency and operating hours and noise data should be provided.

The above information is required to consider the potential risk for adverse noise impacts to nearby residents.

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.