

**Response to Application APP/26/00568 at One Stop Shop, Baybridge Road, Havant,
PO9 5PB**

Dear Denise,

Thank you for confirming that the agent has agreed to reduce the illumination intensity to 300 candela per square metre.

On this basis, I am happy to recommend no objections to the application, subject to the following condition:

Condition:

The illumination of the consented sign(s) shall be no greater than 300 candela per square metre, and the external LED downlighters shall be positioned, angled and shielded to direct light onto the signage only and prevent glare or dazzle to users of the public highway and neighbouring properties.

Reason: In the interests of highway safety and visual amenity.

Please let me know if you would like a formal consultation response to be submitted, or if you are content for this email to serve as my response.

Kind regards,

Thomas Willcox

Assistant Transport Planner – Highways Development Planning

Hampshire County Council

3rd Floor Elizabeth II Court North, The Castle,

Winchester, Hampshire, SO23 8UJ