

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX



Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/18/00234

Our Ref
PLAN-022237

Date
19/11/2018

Dear Sirs,

Proposal: Demolition of existing shopping parade and redevelopment of the site to provide a nine storey building consisting of 264No. 1 bed/studio build to rent apartments and associated amenity facilities, a D2 gym and A3 cafe, together with associated parking and landscaping.

Site: Wellington Way and 95-101A London Road, Waterlooville, PO7 7ED.
APP/18/00234

Further to our correspondence dated 03/04/2018 concerning the above planning application consultation, Southern Water has now undertaken more detailed network modelling as part of a network growth review.

The results of this assessment, to our current Modelling procedures and criteria, indicates that the additional foul sewerage flows from the proposed development will not increase the risk of flooding in the existing public sewerage network. Southern Water can hence facilitate foul sewerage disposal to service the proposed development.

Southern Water requires a formal application for a connection to the public sewer to be made by the applicant. We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development. Please contact Southern Water, Sparrowgrove House Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk". Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on

our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>. "

The results of surface water assessment indicate that with connection at the "practical point of connection" as defined in the New Connections Services implemented from 1st April 2018 that there is an increased risk of flooding if the proposed surface water run off rates are to be discharged at proposed connection points.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of surface water run off disposal in accordance with Part H3 of Building Regulations hierarchy as well as acceptable discharge points, rates and volumes have been agreed by the Lead Flood Authority, in consultation with Southern Water."


It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order:

- a Adequate soakaway or infiltration system
- b Water course
- c Where neither of the above is practicable sewer

Alternatively, the developer can discharge surface water flow no greater than existing levels if proven to be connected and it is ensured that there is no overall increase in flows into the surface water system. You will be required to provide a topographical site survey and/or a CCTV survey showing the existing connection points, pipe sizes, gradients and calculations confirming the proposed surface water flow will be no greater than the existing contributing flows.

All other comments in our response dated 03/04/2018 remain valid.

Yours sincerely



Developer Services