
Ref: PR202606-112396 (APP/26/00423)

From Milligan, Craig <Craig.Milligan@havant.gov.uk>

Date Fri 24/07/2026 11:46

To Fox, Jennie <Jennie.Fox@havant.gov.uk>; Havant Planning and Development Mailbox New
<planning.developmentnew@havant.gov.uk>

Planning Application Reference: APP/26/00423

Description: Discharge of conditions 3 & 11 of planning permission APP/21/01451

Location: Southleigh Park House, Eastleigh Road, Havant, PO9 2PE

Condition 11 - Acoustic barriers

The Trinity Rose drawing entitled 'Double-skin brick wall Piers with feature brick capping detail' (dated 25/03/2026), and the 24 Acoustics report reference R9060-1 Rev 7 (20 February 2025) have been reviewed.

The proposed wall is sufficient for areas where the acoustic report identified that 2m high walls were required at garden boundaries. However, the 24 acoustic report indicates that some plots rely upon 2m high acoustic barrier fencing, and plots 25, 26, and 27 rely upon walls 2.5m high.

Further information is therefore required to include the specifications of the acoustic barrier fencing and 2.5m high walls and that all barrier types achieve the minimum surface density of 12 kg/m² specified by the acoustic model assumptions; and a site plan demonstrating that the different barrier types shall be installed as determined in the 24 Acoustics report reference R9060-1 Rev 7.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health, Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.