Outlook

Fw: Re: FW: Ref: PR202606-111767 (APP/26/00340) 212-218 London Road, Waterlooville, PO7 7AJ

From Fox, Jennie <Jennie.Fox@havant.gov.uk>
Date Fri 02/10/2026 07:59
To Fox, Jennie <Jennie.Fox@havant.gov.uk>

17 attachments (35 KB)
image.png; image.png; image.png; image.png; image.png; image.png; image.png; image.png; image001.png; image.png; image.png; image.png; image.png; image.png; image.png; image.png; image.png;

From: Milligan, Craig
Sent: Thursday, September 03, 2026 10:05
To: Pickup, Tina; Havant Planning and Development Mailbox New
Subject: Fw: Re: FW: Ref: PR202606-111767 (APP/26/00340) 212-218 London Road, Waterlooville, PO7 7AJ

Hi Tina,

I am satisfied that the information regarding ventilation provision and sound insulation of the partitioning floor/ceiling is sufficient.
The upgraded glazing to the front facade is welcomed however, the submitted glazing specification only states Rw values and does not include the Ctr correction term needed to assess performance against the required Rw+Ctr criterion.

As per previous comments, the glazing must achieve 37dB Rw +Ctr.

Further information is requested to demonstrate that the glazing shall achieve the above criteria.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX

Havant BOROUGH COUNCIL
Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.