Outlook

Ref: PR202607-113511 - (APP/26/00525) - Wade Court Cottage, Wade Lane, Havant, PO9 2TB

From Milligan, Craig <Craig.Milligan@havant.gov.uk>
Date Fri 2026-10-02 12:36 PM
To Riley, Robert <Robert.Riley@havant.gov.uk>; Havant Planning and Development Mailbox New <planning.developmentnew@havant.gov.uk>

Planning Application Reference: APP/26/00525
Description: Installation of sewage treatment plant.
Location: Wade Court Cottage, Wade Lane, Havant, PO9 2TB

I have accessed the data sheet for the proposed GRAF 5PE ONE2CLEAN 3,750L online and the noise level is detailed as 36dB. Environmental Health has no objection based on noise concerns.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX

Havant BOROUGH COUNCIL

Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.