

Planning Application Reference: APP/26/00525

Description: Installation of sewage treatment plant.

Location: Wade Court Cottage, Wade Lane, Havant, PO9 2TB

I have accessed the data sheet for the proposed GRAF 5PE ONE2CLEAN 3,750L online and the noise level is detailed as 36dB. Environmental Health has no objection based on noise concerns.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX