

Planning Application Reference: APP/26/00571

Description: Discharge of conditions 3,4,6,11,13,14,16,17,19,20,21,22,23,24 and 25 of Planning Permission APP/25/00639 (28.05.26).

Location: Proposed Development site (former Electricity Board site), Bartons Road, Havant

Condition 19

The Stonebond document entitled 'Construction Environmental Management Plan & Method Statement V2 | Bartons Road, Havant' has been reviewed.

I am satisfied that the revised plan has addressed previous issues raised regarding noise monitoring and dust control measures.

It is understood that the BS5228:2009+A1:2014 ABC method threshold of 65dB(A) LAeq, T shall be adopted at noise sensitive receptors, with an additional threshold of 75dB(A) at noise-sensitive receptors applied as an absolute noise limit for noise resulting from construction activities. It is further understood that should noise levels be found to be approaching these levels an investigation would be undertaken by the site manager and further noise mitigation measures implemented.

Based on the above, Environmental Health (pollution) is satisfied that the submitted information is sufficient to recommend that the condition may be discharged.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX