

Agents Response to request following Environmental Health Response of 25 August 2026

The proposed substations shall feature a generator access point. This is required in the event that there is a failure to the main power supply to the substation and thus a temporary generator would be required to power the substation to ensure that the EV chargers can operate.

The generator access point shall serve no other purpose besides this and as such, will only be used in this scenario. As such, it is not possible to provide details of the frequency and operating hours of the generator, as the need/frequency will be dependent on unpredictable circumstances.