
Re: APP/26/00097 - Discharge of Condition 9 of APP/25/00204

From Milligan, Craig <Craig.Milligan@havant.gov.uk>

Date Fri 09/10/2026 09:41

To Fox, Jennie <Jennie.Fox@havant.gov.uk>

Hi Jennie,

I am satisfied that the submitted information meets the requirements of the condition.

Whilst noise is not included in the condition, the applicant is advised that the air source heat pump should be installed such that noise from the heat pump meets the sound assessment criteria detailed in MCS 020 a).

Noise from the heat pump cannot be controlled by the planning regime at this stage in the application process due to the lack of a relevant condition. However, enforcement action could still be taken by the Local Authority if noise from the heat pump results in statutory noise nuisance at a neighbouring premises.

Kind regards

Craig Milligan

Environmental Health Officer

Environmental Health, Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.

From: Fox, Jennie <Jennie.Fox@havant.gov.uk>

Sent: 01 October 2026 10:30

To: Milligan, Craig <Craig.Milligan@havant.gov.uk>

Subject: APP/26/00097 - Discharge of Condition 9 of APP/25/00204

Hi Craig,

I'm spending an exciting morning checking through all my DOCs (yay).

You should have had a reconsultation for this one back in July after the agent sent the attached additional information through. Do you have any further comments?

Many thanks,

Jennie Fox

Planning Officer | T: 07880 777478

Development Management

Planning Services

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

Working pattern: Monday – Friday

Advance Notice of Leave: N/A

Certified Carbon Literate



In August 2025, the council moved to a new case management system, across Planning Development, Licensing and Environmental Health. This change involved moving 25 years' worth of data from multiple systems into one new system and learning how to use the new system.

Our officers have been working hard to continue working throughout the change, but there was a period of downtime, and we are still working through some of the backlog. As a result, our response times are longer than usual, and we apologise for any inconvenience this may cause.

Thank you for your understanding and patience.

Your privacy matters. Go to havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.