

Havant Borough Council - Development
Control
By Email

Reference: PA-0012685/01
Customer reference: APP/26/00607
12 October 2026

Dear Planning Officer,

Discharge of Conditions 20, 27 & 33 of Planning Application APP/24/00405 relating to (20) Pollution Management and Mitigation Plan, (27) Noise and Vibration Monitoring, (33) Details of Works Area/Compounds.

Havant Thicket, adjacent to Sir George Staunton Country Park, Middle Park Way, Havant

Thank you for consulting the Environment Agency on the discharge of conditions for the above planning application. We have the following comments to make.

I can confirm that we have reviewed the submitted Pollution Management and Mitigation Plan and we have no specific issues with any of the proposed Management and Mitigation safeguards. It should however be noted there is no reference to the public water supply abstraction and sensitive groundwater just beneath the surface. These are very sensitive receptors and should really be specifically referenced in the plan. The basic safeguards proposed are however fundamentally acceptable.

Most/all the work proposed under this phase of the development appears to take place on Portsmouth Water's production site. It is Portsmouth water's responsibility to ensure that any contractors working on their site, follow all relevant safeguards to ensure protection of their assets.

If you have any questions regarding our response, please contact planningssd@environment-agency.gov.uk.

Yours sincerely,

Laura Lax,
National Contact Centre: 03708 506 506
planningssd@environment-agency.gov.uk

Romsey Depot, The Gables, Canal Walk, Romsey, Hampshire, SO51 7LP