
Ref: PR202609-114502 (APP/26/00373) - Waterloo Park, Elettra Avenue, Waterlooville

From Milligan, Craig <Craig.Milligan@havant.gov.uk>

Date Fri 2026-10-23 12:37 PM

To Riley, Robert <Robert.Riley@havant.gov.uk>; Havant Planning and Development Mailbox New
<planning.developmentnew@havant.gov.uk>

Planning Application Reference: APP/26/00373

Description: Discharge of conditions 9 and 15 of Planning Permission APP/21/00399 (04.10.24) .

Location: Waterloo Park, Elettra Avenue, Waterlooville

Condition 15

Having reviewed the Purified Air Impact Statement – KFC Waterlooville (dated 25th September 2026) and the Airflow Cooling Drawing entitled 'PROPOSED VENTILATION LAYOUT | DRAWING NO.

I0001410-KZH-00-DR-02 Rev 2' (dated 25th September 2026) I am satisfied that the submitted information is sufficient to discharge the condition.

The determination is based upon the declaration from Purified Air that the system is fully EMAQ compliant with the use of both ESP and UVO technology present and therefore will provide a very high level of odour control. The submitted noise information indicates that adverse impact is not likely to occur due to the separation distance to the nearest noise-sensitive receptor.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.